

TECHNICAL SPECIFICATIONS FOR MODEL UBXC

**COMMERCIAL/INDUSTRIAL POWER-VENTED HIGH-STATIC BLOWER FAN
CONVERTABLE GAS-FIRED UNIT HEATER**



TABLE OF CONTENTS

Unit Sizes	2
Features	2
Factory-Installed Options	2
Field-Installed Options	3
Certification	4
Installation Codes	4
Technical Data	4
Clearances	5
Dimensions	6
Weights	7
Hazards of Chlorine	7
Gas Supply Pressure	8
Gas Supply Piping	8
Vent Connections	9
Heater Throw Distances with Standard Horizontal Louvers	9
Blower Performance Data for Unit Sizes 30–125 with Direct-Drive Blower Motors	14
Blower Performance Data for Unit Sizes 150–400	17

In keeping with our policy of continuous product improvement, we reserve the right to alter, at any time, the design, construction, dimensions, weights, etc., of equipment information shown here.

TECHNICAL SPECIFICATIONS—CONTINUED

Unit Sizes

These heaters are available in fourteen unit sizes based on 30,000–400,000 BTU_h input.

Features

- Voltage/phase/Hz options: 115/1/60, 208/1/60, 230/1/60, 208/3/60, 230/3/60, 460/3/60, and 575/3/60
- 82–83% thermal efficient
- May be converted to separated-combustion for use in installation locations where dirt, dust, or other airborne contaminants are present in the indoor environment
- Natural gas standard (propane conversion kit available)
- Integrated circuit board with seven-segment display
- Easily-viewed status-indicating LED
- Hinged access door panel with quarter-turn latch
- Improved cabinet design with removable front face
- Two-toned black and white glossy, scratch-resistant paint scheme
- Patented single-burner combustion system
- T_{CORE}²® titanium-stabilized aluminized-steel heat exchanger
- External terminal strip for 24V wiring
- Built-in disconnect switch
- Four-point suspension standard on all unit sizes

Factory-Installed Options

Some options are not available on all unit sizes. Motor options AL2–AL26 are not available for unit sizes 30–125.

Option	Description
AC1	Aluminized-steel heat exchanger
AC2	409 SST heat exchanger
AC4	316 SST heat exchanger
AG1	Single-stage combination gas valve
AG2	Two-stage combination gas valve
AK1	115/1/60 voltage
AK2	208/1/60 voltage
AK3	230/1/60 voltage
AK5	208/3/60 voltage
AK6	230/3/60 voltage
AK7	460/3/60 voltage
AK8	575/3/60 voltage
AL2	1/4-HP open drip-proof motor
AL3	1/3-HP open drip-proof motor
AL4	1/2-HP open drip-proof motor
AL5	3/4-HP open drip-proof motor
AL6	1-HP open drip-proof motor
AL7	1-1/2-HP open drip-proof motor
AL8	2-HP open drip-proof motor
AL9	3-HP open drip-proof motor
AL10	5-HP open drip-proof motor
AL19	1/4-HP totally-enclosed motor
AL20	1/3-HP totally-enclosed motor
AL21	1/2-HP totally-enclosed motor
AL22	3/4-HP totally-enclosed motor
AL23	1-HP totally-enclosed motor
AL24	1-1/2-HP totally-enclosed motor
AL25	2-HP totally-enclosed motor

Option	Description
AL26	3-HP totally-enclosed motor
AM1	401–450 RPM belt drive
AM2	451–500 RPM belt drive
AM3	501–550 RPM belt drive
AM4	551–600 RPM belt drive
AM5	601–650 RPM belt drive
AM6	651–700 RPM belt drive
AM7	701–750 RPM belt drive
AM8	751–800 RPM belt drive
AM9	801–850 RPM belt drive
AM10	851–900 RPM belt drive
AM11	901–950 RPM belt drive
AM12	951–1000 RPM belt drive
AM13	1001–1050 RPM belt drive
AM14	1051–1100 RPM belt drive
AM15	1101–1150 RPM belt drive
AM16	1151–1200 RPM belt drive
AM17	1201–1250 RPM belt drive
AM18	1251–1300 RPM belt drive
AM19	1301–1350 RPM belt drive
AN2	IEC contactor (standard unless starter is required)
AN10	IEC starter
AX4	Duct flange
AZ6	Inlet blower and belt guard
AZ7	Inlet blower guard
BY1	US rating plate
BY3	US/Canada rating plate
DR1	Direct-drive blower
DR4	Belt-drive blower

Field-Installed Options

Option	Description
CC1	Vent cap
CD1	Vertical louvers, direct discharge air to provide wider throw pattern
CD2	Downturn nozzle, 25- to 65-degree variable air deflection range
CD3	Downturn nozzle, 50- to 90-degree variable air deflection range
CD4	Downturn nozzle, 25- to 65-degree variable air deflection range with vertical louvers
CD5	Downturn nozzle, 50- to 90-degree variable air deflection range with vertical louvers
CD9	Duct flange
CD10	Inlet blower and belt guard
CD11	Polytube adapter
CD12	Inlet blower guard
CE1	Manual shutoff valve, natural gas or propane
CG1	208V–115V stepdown transformer
CG4	230V–115V or 460V–115V stepdown transformer
CG5	575V–115V stepdown transformer
CK10	Adapts 3/8-inch hangers for four-point suspension from 1-inch threaded pipe
CL1	Single-stage thermostat
CL22, CL23, CL83, CL84, CL90	Two-stage thermostat
CL31, CL32	Multiple unit control: option CL31 includes components for one control unit and one additional unit—option CL32 includes components for each additional non-control unit
CM1	Locking cover for CL1 thermostat
CM1B	Locking cover for CL22 thermostat
CM3	Bracket assembly for mounting thermostat on unit
DJ20	High-elevation pressure switch
DL2	Propane conversion
SC1	Separated-combustion conversion (requires either vertical (option CC2) or horizontal (option CC6) vent/combustion air inlet terminal kit)

TECHNICAL SPECIFICATIONS—CONTINUED

Certification

These unit heaters are listed by Intertek for use in industrial and commercial installations in the United States and Canada.

Installation Codes

- These units must be installed in accordance with local building codes. In the absence of local codes, in the United States, the unit must be installed in accordance with the *National Fuel Gas Code* (ANSI Z223.1, latest edition). A Canadian installation must be in accordance with the *Natural Gas and Propane Installation Code* (CSA B149, latest edition). This code is available from CSA Information Services, 1-800-463-6727. Local authorities having jurisdiction should be consulted before installation is made to verify local codes and installation procedure requirements.
- Installations in aircraft hangars should be in accordance with the *Standard for Aircraft Hangars* (ANSI/NFPA No. 409, latest edition). Installations in public garages should be in accordance with the *Standard for Parking Structures* (ANSI/NFPA No. 88A, latest edition). Installations in repair garages should be in accordance with the *Standard for Repair Garages* (ANSI/NFPA No. 88B, latest edition). In Canada, installations in aircraft hangars should be in accordance with the requirements of the enforcing authorities, and in public garages, in accordance with the CSA B149 code.
- If the heater is being installed in the Commonwealth of Massachusetts, installation must be performed by a licensed plumber or licensed gas fitter.

Technical Data

Parameter	Unit of Measure	Unit Size (MBTUh)					
		30	45	60	75	100	125
Thermal efficiency	%	82		82		83	
Input heating capacity	BTUh	30,000	45,000	60,000	75,000	105,000	120,000
	kW	8.8	13.2	17.6	22.0	30.8	35.2
Output heating capacity, low fire*	BTUh	17,220	25,830	34,440	43,050	61,005	69,720
	kW	5.0	7.6	10.1	12.6	17.9	20.4
Output heating capacity, high fire*	BTUh	24,600	36,900	49,200	61,500	87,150	99,600
	kW	7.2	10.8	14.4	18.0	25.6	29.2
Gas connection**	inch	1/2					
Vent connection diameter***		4					
Control, 24V	amp	1.0					
Full load amps, 115V		3.7		7.1		13.0	
Maximum overcurrent protection, 115V†		15		15		30	
Normal power consumption	watt	215		447		537	
Discharge air temperature rise	°F	45–75					
	°C	7–24					
Minimum air volume	CFM	304	456	607	759	1076	1230
	meter ³ /minute	8.6	12.9	17.2	21.5	30.5	34.8
Maximum air volume	CFM	506	759	1012	1265	1793	2049
	meter ³ /minute	14.3	21.5	28.7	35.8	50.8	58.0
Discharge air opening area	foot ²	0.96		1.25		2.01	
	meter ²	0.09		0.12		0.19	
Minimum output velocity	FPM	316	475	486	607	535	612
	meter/minute	96	143	143	179	160	183
Maximum output velocity	FPM	527	791	810	1012	892	1020
	meter/minute	159	239	239	299	267	305
Standard blower motor horsepower	HP	1/6		1/3		1/3	
Blower fan size	inch	9 × 6		9 × 6		10 × 10	
Sound level @ 15 feet	dBa	40		40	49	54	55
*ETL ratings for elevations up to 2,000 feet.							
**Size shown is for natural gas or propane gas connection to a single-stage gas valve—not supply line size.							
***Smaller and/or larger vent and combustion air pipe diameters may be permissible.							
†MOCP = 2.25 × (largest motor FLA) + smallest motor FLA. Answer is rounded to the next lower standard circuit breaker size.							

Parameter	Unit of Measure	Unit Size (MBTUh)							
		150	175	200	225	250	300	350	400
Thermal efficiency	%	83				83			82
Input heating capacity	BTUh	150,000	175,000	200,000	225,000	250,000	300,000	350,000	400,000
	kW	43.9	51.2	58.6	65.9	73.2	87.8	102.5	117.1
Output heating capacity, low fire*	BTUh	87,150	101,675	116,200	130,725	145,250	174,300	203,350	229,600
	kW	25.5	29.8	34.0	38.3	42.6	51.0	59.6	67.2
Output heating capacity, high fire*	BTUh	124,500	145,250	166,000	186,750	207,500	249,000	290,500	328,000
	kW	36.4	42.5	48.6	54.7	60.8	72.9	85.1	96.0
Gas connection**	inch	1/2			3/4	3/4			
Vent connection diameter***		5			5	6			
Control, 24V	amp	1.0							
Full load amps, 115V		5.9	9.6	10.5	12.7	12.7	17.7	27.3	
Maximum overcurrent protection, 115V†		15	20	25	30	30	40	60	
Normal power consumption	watt	230	415	485	675	675	1260	1635	
Discharge air temperature rise	°F	45–75				45–75			50–80
	°C	7–24				7–24			10–27
Minimum air volume	CFM	1537	1793	2049	2306	2562	3074	3586	4100
	meter ³ /minute	43.5	50.8	58.0	65.3	72.5	87.0	101.5	116.1
Maximum air volume	CFM	2562	2989	3416	3843	4270	5123	5977	6185
	meter ³ /minute	72.5	84.6	96.7	108.8	120.9	145.1	169.2	175.1
Discharge air opening area	foot ²	2.56			3.51	3.51	4.79	4.79	
	meter ²	0.24			0.33	0.33	0.45	0.45	
Minimum output velocity	FPM	600	700	800	657	730	642	749	856
	meter/minute	183	213	244	200	223	196	228	261
Maximum output velocity	FPM	1001	1168	1334	1095	1217	1070	1248	1291
	meter/minute	305	356	407	334	371	326	380	393
Standard blower motor horsepower	HP	1/4	1/2	1/2	3/4	3/4	1-1/2	2	
Blower fan size	inch	12 × 12			15 × 11	15 × 11		15 × 15	
Sound level @ 15 feet	dBa	51	52	53	56	56	59	61	62
*ETL ratings for elevations up to 2,000 feet.									
**Size shown is for natural gas or propane gas connection to a single-stage gas valve—not supply line size.									
***Smaller and/or larger vent and combustion air pipe diameters may be permissible.									
†MOCP = 2.25 × (largest motor FLA) + smallest motor FLA. Answer is rounded to the next lower standard circuit breaker size.									

Clearances

Units must be located so that clearances are provided for with regards to combustion air space, inspection, and service and for proper spacing from combustible construction. Clearance to combustibles is defined as the minimum distance from the heater to a surface or object for which it is necessary to ensure that a surface temperature of 90°F (50°C) above the surrounding ambient temperature is not exceeded.


Heater Surface	Unit Size (MBTUh)	
	30–125	150–400
	Minimum Clearance (Inches (mm))	
Top	1 (25)	4 (102)
Flue connector	6 (152)	6 (152)
Access panel	18 (457)	18 (457)
Non-access side	1 (25)	2 (51)
Bottom*	1 (25)	1 (25)
Rear**	18 (457)	18 (457)
Front	Refer to values for variable X (distance from heater to start of floor coverage) in Heater Throw Distances with Standard Horizontal Louvers section	

*Suspend the heater so that the bottom is a minimum of 5 feet (1.5 meters) above the floor.





**Measure rear clearance from the fan motor.

TECHNICAL SPECIFICATIONS—CONTINUED

Dimensions



DIRECT-DRIVE BLOWER (UNIT SIZES 100–125)



Dimension (See Graphic Above)	Unit Size (MBTUh)								
	30, 45	60	75	100	125	150, 175	200	225, 250	300, 350, 400
	Inches (mm)								
A	27 (686)					38-3/16 (970)			41 (1041)
B	13-3/4 (349)	16-3/4 (425)		24-3/4 (629)		20-1/8 (511)		26-1/8 (664)	34-1/8 (867)
C	13-13/16 (351)					23 (584)			
D	10 (254)	13 (330)		21 (533)		16 (406)		22 (559)	30 (762)
E*	17-3/16 (437)	18-11/16 (475)		24-1/16 (611)		30-31/32 (786)		37-1/32 (941)	41-7/32 (1047)
F	40-3/32 (1018)			48-1/8 (1222)	47-5/8 (1210)	64-3/4 (1645)		68-1/8 (1730)	
G	25-17/32 (649)					40 (1016)			
H**	17-3/8 (441)					25-11/16 (653)			27-11/16 (703)
J	1-9/16 (40)					1-13/32 (36)			
K**	22-1/2 (572)					24-1/2 (622)			23-1/2 (597)
L	6-15/32 (164)		5-15/32 (139)	8-15/32 (215)	7-15/32 (190)	3-29/32 (99)		5-29/32 (150)	1-13/32 (36)
M	10 (254)	12-11/16 (322)		19-5/16 (491)		13-1/2 (343)	14-9/16 (370)	18-1/16 (459)	22-9/16 (573)
N	6 (152)	8-11/16 (221)		15-5/16 (389)		8-1/2 (216)	9-9/16 (243)	13-1/16 (332)	17-1/16 (433)
P	3-1/2 (89)	6-5/16 (160)		9-9/16 (243)		5-7/16 (138)		9 (229)	11-13/16 (300)
Q	2-21/32 (74)					4-3/16 (106)			4-1/2 (114)
R	5-31/32 (152)	3-5/16 (84)				6-1/2 (165)			7-5/16 (186)
S	3-5/16 (84)	5-29/32 (150)				8-3/16 (208)			8-1/2 (216)
T	31 (787)					42 (1067)			
*Varies with motor selection and belt adjustment for unit sizes 150–400.									
**Heater suspension points (3/8-16 FEM).									

Weights

Type	Unit Size (MBTUh)												
	30	45	60	75	100	125	150	175, 200	225	250	300	350	400
	Pounds (kg)												
Unit	84 (38)	89 (40)	102 (46)	108 (49)	168 (76)	171 (78)	300 (136)	320 (145)	385 (175)	400 (181)	458 (208)	494 (224)	506 (230)
Shipping	94 (43)	99 (45)	114 (52)	120 (54)	182 (83)	187 (85)	322 (146)	342 (155)	409 (186)	424 (192)	484 (220)	520 (236)	536 (243)

Hazards of Chlorine

The presence of chlorine vapors in the combustion air of gas-fired heating equipment presents a potential corrosion hazard for separated-combustion heaters with regard to the combustion air inlet. Chlorine is usually found in the form of freon or degreaser vapors. When chlorine is exposed to flame, it will precipitate from the compound and go into solution with any condensation that is present in the heat exchanger or associated parts. The result is hydrochloric acid, which readily attacks all metals including 300 grade stainless steel. Care should be taken to separate these vapors from the combustion process. This may be done by wise location of the unit vent and combustion air terminals with regard to exhausters or prevailing wind directions. Chlorine is heavier than air. Keep these facts in mind when determining installation location of the heater in relation to building exhaust systems.

TECHNICAL SPECIFICATIONS—CONTINUED

Gas Supply Pressure

- The unit is equipped for a maximum gas supply pressure of 1/2 psi, 3.5 kPa, or 14 IN WC for natural gas or propane. The minimum supply pressure, as measured while the unit is operating at full fire, is 5 IN WC for natural gas or 11 IN WC for propane.
- Supply pressure higher than 1/2 psi requires the installation of an additional service regulator external to the unit.
- **Pressure testing supply piping:** For test pressures *above* 1/2 psi, disconnect the heater and manual valve from the gas supply line to be tested and cap or plug the supply line. For test pressures *below* 1/2 psi, before testing, close the manual valve on the heater.

Gas Supply Piping

- All piping must be in accordance with requirements outlined in the *National Fuel Gas Code* (ANSI/Z223.1, latest edition) or the *Natural Gas and Propane Installation Code* (CSA B149.1, latest edition).
- The heater is orificed for operation with natural gas having a heating value of 1,050 (±50) BTU per cubic foot or with propane gas having a heating value of 2,550 (±100) BTU per cubic foot. Sizing of gas supply lines depends on piping capacity and is based on cubic feet per hour based on a 0.3 IN WC pressure drop, a 0.6 specific gravity for natural gas at 1,050 BTU per cubic feet, and a 1.6 specific gravity for propane at 2,550 BTU per cubic feet. If the gas at the installation does not meet this specification, consult the factory for proper orificing.
- Variables for sizing gas supply lines are listed in the table below. When sizing supply lines, consider possibilities of future expansion and increased requirements. Refer to the *National Fuel Gas Code* for additional information on line sizing.

Length of Pipe (Feet)	Diameter of Pipe (Inches)											
	1/2		3/4		1		1-1/4		1-1/2		2	
	Natural Gas	Propane	Natural Gas	Propane	Natural Gas	Propane	Natural Gas	Propane	Natural Gas	Propane	Natural Gas	Propane
	Cubic Feet per Hour											
20	92	56	190	116	350	214	730	445	1100	671	2100	1281
30	73	45	152	93	285	174	590	360	890	543	1650	1007
40	63	38	130	79	245	149	500	305	760	464	1450	885
50	56	34	115	70	215	131	440	268	670	409	1270	775
60	50	31	105	64	195	119	400	244	610	372	1105	674
70	46	28	96	59	180	110	370	226	560	342	1050	641
80	43	26	90	55	170	104	350	214	530	323	990	604
90	40	24	84	51	160	98	320	195	490	299	930	567
100	38	23	79	48	150	92	305	186	460	281	870	531
125	34	21	72	44	130	79	275	168	410	250	780	476
150	31	19	64	39	120	73	250	153	380	232	710	433
175	28	17	59	36	110	67	225	137	350	214	650	397
200	26	16	55	34	100	61	210	128	320	195	610	372

Vent Connections

Vent system methods vary depending on whether the vent is dedicated or common and whether the unit is standard or separated-combustion. Refer to the installation manual provided with the unit and select and follow the venting instructions that apply to the installation only. For venting separated-combustion units, refer to the installation manual provided with the unit as well as the separated-combustion conversion instructions provided with the conversion kit.


⚠ CAUTION ⚠

- When an existing appliance is removed or replaced in a venting system, verify that the venting system is properly sized to vent the new appliance. An improperly sized venting system may result in the formation of condensate, leakage, and/or spillage.
- Do not intermix different vent system parts from different manufacturers in the same venting system.

NOTE: Venting must be in accordance with local codes and with the *National Fuel Gas Code* (ANSI Z223.1) or the *Installation Code for Gas Burning Appliances and Equipment* (CSA B149.1). Local requirements supersede national requirements.

Heater Throw Distances with Standard Horizontal Louvers

The graphic shows throw patterns and the table lists throw distances for heaters suspended at varying mounting heights. The louver angles listed are relative to the top of the heater. The throw pattern changes with the addition of optional vertical louvers and/or downturn nozzles.



H = Distance from bottom of heater to the floor

X = Distance from heater to start of floor coverage

Y = Distance to end of floor coverage

Z = Distance at which air velocity drops below 50 feet (15.2 meters) per minute

TECHNICAL SPECIFICATIONS—CONTINUED

Heater Throw Distances with Standard Horizontal Louvers—Continued

H* (Feet (Meters))	Distance* or Angle	Low Speed						75°F (42°C) Rise
		Unit Size (MBTUh)						
		30	45	60	75	100	125	150
		Feet (Meters)						
5 (1.5)	X	7 (2.1)	7 (2.1)	11 (3.4)	11 (3.4)	10 (3.0)	10 (3.0)	—
	Y	15 (4.6)	17 (5.2)	26 (7.9)	24 (7.3)	23 (7.0)	22 (6.7)	
	Z	38 (11.6)	44 (13.4)	78 (23.8)	74 (22.6)	74 (22.6)	69 (21.0)	
	Downward louver angle	27°	20°	15°	13°	16°	14°	
8 (2.4)	X	7 (2.1)	9 (2.7)	14 (4.3)	13 (4.0)	13 (4.0)	12 (3.7)	9 (2.7)
	Y	13 (4.0)	17 (5.2)	26 (7.9)	26 (7.9)	25 (7.6)	24 (7.3)	16 (4.9)
	Z	32 (9.8)	40 (12.2)	76 (23.2)	72 (21.9)	72 (21.9)	65 (19.8)	44 (13.4)
	Downward louver angle	44°	34°	23°	23°	25°	24°	39
10 (3.0)	X	7 (2.1)	9 (2.7)	15 (4.6)	15 (4.6)	14 (4.3)	13 (4.0)	9 (2.7)
	Y	11 (3.4)	16 (4.9)	27 (8.2)	25 (7.6)	25 (7.6)	24 (7.3)	14 (4.3)
	Z	25 (7.6)	37 (11.3)	72 (21.9)	69 (21.0)	69 (21.0)	62 (18.9)	38 (11.6)
	Downward louver angle	56°	42°	29°	28°	31°	31°	48°
12 (3.7)	X	—	9 (2.7)	16 (4.9)	15 (4.6)	14 (4.3)	14 (4.3)	7 (2.1)
	Y		14 (4.3)	26 (7.9)	25 (7.6)	24 (7.3)	23 (7.0)	11 (3.4)
	Z		31 (9.4)	70 (21.3)	65 (19.8)	66 (20.1)	58 (17.7)	30 (9.1)
	Downward louver angle		52°	34°	34°	37°	37°	58°
14 (4.3)	X	—	—	16 (4.9)	15 (4.6)	14 (4.3)	14 (4.3)	—
	Y			25 (7.6)	24 (7.3)	23 (7.0)	21 (6.4)	
	Z			65 (19.8)	62 (18.9)	62 (18.9)	54 (16.5)	
	Downward louver angle			40°	40°	43°	43°	
16 (4.9)	X	—	—	15 (4.6)	15 (4.6)	14 (4.3)	12 (3.7)	—
	Y			24 (7.3)	23 (7.0)	21 (6.4)	19 (5.8)	
	Z			60 (18.3)	56 (17.1)	57 (17.4)	47 (14.3)	
	Downward louver angle			46°	46°	49°	51°	
18 (5.5)	X	—	—	14 (4.3)	14 (4.3)	12 (3.7)	11 (3.4)	—
	Y			22 (6.7)	21 (6.4)	18 (5.5)	17 (5.2)	
	Z			53 (16.2)	50 (15.2)	51 (15.5)	40 (12.2)	
	Downward louver angle			52°	52°	56°	57°	
*See graphic above.								

*See graphic above.

H* (Feet (Meters))	Distance* or Angle	Medium Speed						60°F (33°C) Rise
		Unit Size (MBTUh)						
		30	45	60	75	100	125	150
		Feet (Meters)						
5 (1.5)	X	7 (2.1)	9 (2.7)	12 (3.7)	11 (3.4)	11 (3.4)	12 (3.7)	—
	Y	16 (4.9)	21 (6.4)	28 (8.5)	27 (8.2)	27 (8.2)	29 (8.8)	
	Z	43 (13.1)	60 (18.3)	91 (27.7)	84 (25.6)	86 (26.2)	96 (29.3)	
	Downward louver angle	24°	15°	13°	11°	13°	10°	
8 (2.4)	X	9 (2.7)	11 (3.4)	16 (4.9)	15 (4.6)	15 (4.6)	16 (4.9)	13 (4.0)
	Y	16 (4.9)	23 (7.0)	30 (9.1)	29 (8.8)	28 (8.5)	31 (9.4)	24 (7.3)
	Z	38 (11.6)	57 (17.4)	89 (27.1)	82 (25.0)	83 (25.3)	94 (28.7)	74 (22.6)
	Downward louver angle	38°	26°	21°	19°	21°	18°	28°
10 (3.0)	X	8 (2.4)	13 (4.0)	17 (5.2)	16 (4.9)	17 (5.2)	18 (5.5)	13 (4.0)
	Y	14 (4.3)	22 (6.7)	30 (9.1)	30 (9.1)	29 (8.8)	32 (9.8)	22 (6.7)
	Z	33 (10.1)	54 (16.5)	86 (26.2)	79 (24.1)	81 (24.7)	92 (28.0)	62 (18.9)
	Downward louver angle	48°	32°	26°	25°	26°	23°	35°
*See graphic above.								

*See graphic above.

H* (Feet (Meters))	Distance* or Angle	Medium Speed						60°F (33°C) Rise
		Unit Size (MBTUh)						
		30	45	60	75	100	125	150
		Feet (Meters)						
12 (3.7)	X	8 (2.4)	13 (4.0)	18 (5.5)	17 (5.2)	17 (5.2)	19 (5.8)	13 (4.0)
	Y	12 (3.7)	21 (6.4)	31 (9.4)	30 (9.1)	29 (8.8)	32 (9.8)	21 (6.4)
	Z	28 (8.5)	51 (15.5)	83 (25.3)	77 (23.5)	78 (23.8)	89 (27.1)	57 (17.4)
	Downward louver angle	56°	39°	31°	30°	32°	27°	42°
14 (4.3)	X	—	12 (3.7)	18 (5.5)	18 (5.5)	18 (5.5)	20 (6.1)	12 (3.7)
	Y		20 (6.1)	30 (9.1)	29 (8.8)	29 (8.8)	32 (9.8)	19 (5.8)
	Z		46 (14.0)	79 (24.1)	74 (22.6)	74 (22.6)	87 (26.5)	51 (15.5)
	Downward louver angle		46°	36°	34°	37°	32°	49°
16 (4.9)	X	—	11 (3.4)	19 (5.8)	18 (5.5)	18 (5.5)	20 (6.1)	11 (3.4)
	Y		17 (5.2)	29 (8.8)	28 (8.5)	27 (8.2)	31 (9.4)	16 (4.9)
	Z		40 (12.2)	75 (22.9)	70 (21.3)	70 (21.3)	83 (25.3)	43 (13.1)
	Downward louver angle		53°	41°	39°	42°	36°	57°
18 (5.5)	X	—		17 (5.2)	18 (5.5)	17 (5.2)	20 (6.1)	—
	Y			28 (8.5)	26 (7.9)	26 (7.9)	30 (9.1)	
	Z			69 (21.0)	65 (19.8)	64 (19.5)	78 (23.8)	
	Downward louver angle			46°	44°	47°	40°	
*See graphic above.								

*See graphic above.

H* (Feet (Meters))	Distance* or Angle	High Speed						45°F (25°C) Rise
		Unit Size (MBTUh)						
		30	45	60	75	100	125	150
		Feet (Meters)						
5 (1.5)	X	8 (2.4)	11 (3.4)	13 (4.0)	12 (3.7)	13 (4.0)	13 (4.0)	—
	Y	19 (5.8)	28 (8.5)	30 (9.1)	30 (9.1)	32 (9.8)	33 (10.1)	
	Z	51 (15.5)	81 (24.7)	105 (32.0)	97 (29.6)	110 (33.5)	113 (34.4)	
	Downward louver angle	20°	11°	11°	9°	10°	7°	
8 (2.4)	X	10 (3.0)	15 (4.6)	17 (5.2)	17 (5.2)	18 (5.5)	19 (5.8)	18 (5.5)
	Y	19 (5.8)	29 (8.8)	33 (10.1)	33 (10.1)	34 (10.4)	36 (11.0)	32 (9.8)
	Z	48 (14.6)	79 (24.1)	103 (31.4)	95 (29.0)	108 (32.9)	111 (33.8)	107 (32.6)
	Downward louver angle	31°	19°	19°	16°	17°	13°	19°
10 (3.0)	X	11 (3.4)	16 (4.9)	19 (5.8)	19 (5.8)	20 (6.1)	21 (6.4)	19 (5.8)
	Y	19 (5.8)	30 (9.1)	34 (10.4)	33 (10.1)	36 (11.0)	37 (11.3)	34 (10.4)
	Z	44 (13.4)	78 (23.8)	100 (30.5)	94 (28.7)	106 (32.3)	109 (33.2)	104 (31.7)
	Downward louver angle	39°	24°	23°	20°	21°	17°	24°
12 (3.7)	X	11 (3.4)	17 (5.2)	21 (6.4)	20 (6.1)	22 (6.7)	23 (7.0)	21 (6.4)
	Y	17 (5.2)	30 (9.1)	35 (10.7)	34 (10.4)	36 (11.0)	39 (11.9)	34 (10.4)
	Z	40 (12.2)	75 (22.9)	98 (29.9)	92 (28.0)	104 (31.7)	107 (32.6)	102 (31.1)
	Downward louver angle	46°	29°	27°	25°	25°	21°	28°
14 (4.3)	X	9 (2.7)	18 (5.5)	22 (6.7)	21 (6.4)	23 (7.0)	24 (7.3)	22 (6.7)
	Y	15 (4.6)	30 (9.1)	34 (10.4)	34 (10.4)	36 (11.0)	39 (11.9)	34 (10.4)
	Z	33 (10.1)	72 (21.9)	95 (29.0)	89 (27.1)	102 (31.1)	105 (32.0)	98 (29.9)
	Downward louver angle	56°	34°	31°	29°	29°	25°	32°
16 (4.9)	X	—	19 (5.8)	23 (7.0)	22 (6.7)	24 (7.3)	25 (7.6)	22 (6.7)
	Y		29 (8.8)	33 (10.1)	33 (10.1)	36 (11.0)	40 (12.2)	33 (10.1)
	Z		69 (21.0)	91 (27.7)	86 (26.2)	99 (30.2)	103 (31.4)	94 (28.7)
	Downward louver angle		39°	35°	33°	33°	29°	36°
18 (5.5)	X	—	18 (5.5)	21 (6.4)	22 (6.7)	23 (7.0)	26 (7.9)	21 (6.4)
	Y		28 (8.5)	33 (10.1)	33 (10.1)	36 (11.0)	39 (11.9)	33 (10.1)
	Z		64 (19.5)	86 (26.2)	83 (25.3)	95 (29.0)	101 (30.8)	89 (27.1)
	Downward louver angle		44°	40°	37°	37°	32°	41°
*See graphic above.								

*See graphic above.

TECHNICAL SPECIFICATIONS—CONTINUED

Heater Throw Distances with Standard Horizontal Louvers—Continued

H* (Feet (Meters))	Distance* or Angle	75°F (42°C) Rise						80°F (44°C) Rise
		Unit Size (MBTUh)						
		175	200	225	250	300	350	400
		Feet (Meters)						
8 (2.4)	X	12 (3.7)	13 (4.0)	13 (4.0)	14 (4.3)	12 (3.7)	13 (4.0)	15 (4.6)
	Y	22 (6.7)	24 (7.3)	24 (7.3)	27 (8.2)	21 (6.4)	25 (7.6)	28 (8.5)
	Z	69 (21.0)	76 (23.2)	82 (25.0)	95 (29.0)	70 (21.3)	82 (25.0)	95 (29.0)
	Downward louver angle	30°	27°	29°	26°	32°	27°	24°
10 (3.0)	X	12 (3.7)	14 (4.3)	12 (3.7)	16 (4.9)	12 (3.7)	14 (4.3)	16 (4.9)
	Y	22 (6.7)	24 (7.3)	21 (6.4)	27 (8.2)	21 (6.4)	25 (7.6)	28 (8.5)
	Z	65 (19.8)	72 (21.9)	66 (20.1)	91 (27.7)	65 (19.8)	77 (23.5)	92 (28.0)
	Downward louver angle	37°	33°	38°	31°	39°	33°	29°
12 (3.7)	X	13 (4.0)	14 (4.3)	12 (3.7)	16 (4.9)	12 (3.7)	14 (4.3)	17 (5.2)
	Y	21 (6.4)	23 (7.0)	20 (6.1)	27 (8.2)	19 (5.8)	24 (7.3)	28 (8.5)
	Z	59 (18.0)	68 (20.7)	60 (18.3)	86 (26.2)	58 (17.7)	72 (21.9)	88 (26.8)
	Downward louver angle	43°	39°	45°	37°	47°	40°	34°
14 (4.3)	X	11 (3.4)	14 (4.3)	11 (3.4)	16 (4.9)	10 (3.0)	14 (4.3)	17 (5.2)
	Y	19 (5.8)	22 (6.7)	18 (5.5)	25 (7.6)	17 (5.2)	22 (6.7)	27 (8.2)
	Z	52 (15.8)	62 (18.9)	53 (16.2)	80 (24.4)	50 (15.2)	66 (20.1)	82 (25.0)
	Downward louver angle	51°	46°	52°	43°	55°	46°	39°
16 (4.9)	X	—	12 (3.7)	—	16 (4.9)	—	13 (4.0)	17 (5.2)
	Y		20 (6.1)		23 (7.0)		20 (6.1)	26 (7.9)
	Z		53 (16.2)		73 (22.3)		57 (17.4)	76 (23.2)
	Downward louver angle		53°		49°		53°	45°
18 (5.5)	X	—			14 (4.3)	—		16 (4.9)
	Y				21 (6.4)			24 (7.3)
	Z				64 (19.5)			69 (21.0)
	Downward louver angle				56°			50°
*See graphic above.								

*See graphic above.

H* (Feet (Meters))	Distance* or Angle	60°F (33°C) Rise						70°F (39°C) Rise
		Unit Size (MBTUh)						
		175	200	225	250	300	350	400
		Feet (Meters)						
8 (2.4)	X	15 (4.6)	16 (4.9)	16 (4.9)	19 (5.8)	16 (4.9)	18 (5.5)	17 (5.2)
	Y	29 (8.8)	31 (9.4)	29 (8.8)	34 (10.4)	28 (8.5)	33 (10.1)	31 (9.4)
	Z	92 (28.0)	100 (30.5)	100 (30.5)	127 (38.7)	100 (30.5)	119 (36.3)	111 (33.8)
	Downward louver angle	22°	21°	24°	20°	24°	20°	21°
10 (3.0)	X	16 (4.9)	18 (5.5)	16 (4.9)	20 (6.1)	17 (5.2)	19 (5.8)	18 (5.5)
	Y	29 (8.8)	31 (9.4)	30 (9.1)	35 (10.7)	29 (8.8)	34 (10.4)	32 (9.8)
	Z	89 (27.1)	97 (29.6)	96 (29.3)	123 (37.5)	96 (29.3)	116 (35.4)	107 (32.6)
	Downward louver angle	28°	25°	29°	24°	29°	25°	26°
12 (3.7)	X	17 (5.2)	19 (5.8)	17 (5.2)	21 (6.4)	18 (5.5)	21 (6.4)	19 (5.8)
	Y	29 (8.8)	31 (9.4)	30 (9.1)	36 (11.0)	29 (8.8)	34 (10.4)	32 (9.8)
	Z	85 (25.9)	93 (28.3)	92 (28.0)	120 (36.6)	92 (28.0)	113 (34.4)	103 (31.4)
	Downward louver angle	33°	30°	34°	28°	34°	29°	31°
14 (4.3)	X	17 (5.2)	20 (6.1)	18 (5.5)	22 (6.7)	18 (5.5)	22 (6.7)	20 (6.1)
	Y	28 (8.5)	30 (9.1)	28 (8.5)	35 (10.7)	28 (8.5)	34 (10.4)	31 (9.4)
	Z	80 (24.4)	89 (27.1)	87 (26.5)	116 (35.4)	87 (26.5)	109 (33.2)	99 (30.2)
	Downward louver angle	38°	34°	38°	32°	39°	33°	35°

*See graphic above.

H* (Feet (Meters))	Distance* or Angle	60°F (33°C) Rise						70°F (39°C) Rise
		Unit Size (MBTUh)						
		175	200	225	250	300	350	400
		Feet (Meters)						
16 (4.9)	X	17 (5.2)	20 (6.1)	18 (5.5)	23 (7.0)	18 (5.5)	22 (6.7)	20 (6.1)
	Y	27 (8.2)	29 (8.8)	27 (8.2)	35 (10.7)	27 (8.2)	33 (10.1)	31 (9.4)
	Z	75 (22.9)	84 (25.6)	80 (24.4)	111 (33.8)	81 (24.7)	104 (31.7)	93 (28.3)
	Downward louver angle	43°	39°	44°	37°	44°	37°	40°
18 (5.5)	X	17 (5.2)	19 (5.8)	17 (5.2)	23 (7.0)	17 (5.2)	22 (6.7)	20 (6.1)
	Y	25 (7.6)	29 (8.8)	26 (7.9)	34 (10.4)	25 (7.6)	32 (9.8)	29 (8.8)
	Z	69 (21.0)	79 (24.1)	74 (22.6)	106 (32.3)	73 (22.3)	98 (29.9)	88 (26.8)
	Downward louver angle	48°	44°	49°	41°	50°	41°	44°

*See graphic above.

H* (Feet (Meters))	Distance* or Angle	45°F (25°C) Rise						50°F (28°C) Rise
		Unit Size (MBTUh)						
		175	200	225	250	300	350	400
		Feet (Meters)						
8 (2.4)	X	22 (6.7)	23 (7.0)	23 (7.0)	26 (7.9)	21 (6.4)	24 (7.3)	24 (7.3)
	Y	41 (12.5)	43 (13.1)	43 (13.1)	48 (14.6)	39 (11.9)	45 (13.7)	44 (13.4)
	Z	146 (44.5)	157 (47.9)	168 (51.2)	198 (60.4)	146 (44.5)	169 (51.5)	169 (51.5)
	Downward louver angle	15°	13°	16°	14°	17°	14°	14°
10 (3.0)	X	24 (7.3)	25 (7.6)	26 (7.9)	29 (8.8)	23 (7.0)	26 (7.9)	26 (7.9)
	Y	43 (13.1)	46 (14.0)	45 (13.7)	50 (15.2)	41 (12.5)	47 (14.3)	46 (14.0)
	Z	144 (43.9)	155 (47.2)	166 (50.6)	196 (59.7)	143 (43.6)	167 (50.9)	167 (50.9)
	Downward louver angle	19°	17°	19°	17°	21°	18°	17°
12 (3.7)	X	26 (7.9)	27 (8.2)	28 (8.5)	31 (9.4)	25 (7.6)	28 (8.5)	28 (8.5)
	Y	43 (13.1)	47 (14.3)	45 (13.7)	52 (15.8)	42 (12.8)	48 (14.6)	48 (14.6)
	Z	141 (43.0)	152 (46.3)	163 (49.7)	194 (59.1)	140 (42.7)	165 (50.3)	165 (50.3)
	Downward louver angle	22°	20°	22°	20°	25°	21°	20°
14 (4.3)	X	28 (8.5)	29 (8.8)	30 (9.1)	32 (9.8)	26 (7.9)	30 (9.1)	31 (9.4)
	Y	44 (13.4)	48 (14.6)	46 (14.0)	54 (16.5)	42 (12.8)	49 (14.9)	48 (14.6)
	Z	137 (41.8)	150 (45.7)	160 (48.8)	191 (58.2)	137 (41.8)	162 (49.4)	162 (49.4)
	Downward louver angle	25°	23°	25°	22°	28°	24°	23°
16 (4.9)	X	29 (8.8)	31 (9.4)	31 (9.4)	34 (10.4)	27 (8.2)	32 (9.8)	32 (9.8)
	Y	44 (13.4)	48 (14.6)	47 (14.3)	53 (16.2)	42 (12.8)	48 (14.6)	49 (14.9)
	Z	134 (40.8)	147 (44.8)	157 (47.9)	189 (57.6)	133 (40.5)	159 (48.5)	159 (48.5)
	Downward louver angle	28°	26°	29°	25°	31°	26°	26°
18 (5.5)	X	29 (8.8)	31 (9.4)	31 (9.4)	34 (10.4)	28 (8.5)	33 (10.1)	32 (9.8)
	Y	44 (13.4)	49 (14.9)	47 (14.3)	54 (16.5)	41 (12.5)	49 (14.9)	49 (14.9)
	Z	131 (39.9)	144 (43.9)	153 (46.6)	185 (56.4)	129 (39.3)	156 (47.5)	156 (47.5)
	Downward louver angle	32°	29°	32°	28°	34°	29°	29°


*See graphic above.

TECHNICAL SPECIFICATIONS—CONTINUED


Blower Performance Data for Unit Sizes 30–125 with Direct-Drive Blower Motors

NOTE: Blower performance data shown below are estimations and are subject to change based on product variations, improvements, and local environmental conditions.


UNIT SIZE 30




UNIT SIZE 45



UNIT SIZE 60




UNIT SIZE 75




TECHNICAL SPECIFICATIONS—CONTINUED

Blower Performance Data for Unit Sizes 30–125 with Direct-Drive Blower Motors—Continued

UNIT SIZE 100



UNIT SIZE 125



Blower Performance Data for Unit Sizes 150–400

NOTE: Blower performance data shown below are estimations and are subject to change based on product variations, improvements, and local environmental conditions.

Unit Size (MBTUh)	Temperature Rise (°F)	CFM	30-Degree Nozzle with Louvers		60-Degree Nozzle with Louvers		External Static Pressure (IN WC)					
							0		0.25		0.50	
			RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP
150	45	2562	730	0.43	730	0.43	730	0.43	840	0.55	930	0.68
	60	1921	520	0.25	520	0.25	520	0.25	655	0.35	780	0.43
	75	1537	405	0.17	405	0.17	405	0.17	—			
175	45	2989	910	0.68	910	0.68	910	0.68	960	0.83	1055	0.98
	60	2242	660	0.44	660	0.44	660	0.44	775	0.51	865	0.63
	75	1793	545	0.28	545	0.28	545	0.28	665	0.38	—	
200	45	3416	1020	0.91	1020	0.91	1020	0.91	1090	1.07	1160	1.24
	60	2562	730	0.49	730	0.49	730	0.49	885	0.63	935	0.76
	75	2049	600	0.34	600	0.34	600	0.34	720	0.45	830	0.51
225	45	3843	740	1.05	740	1.05	740	1.05	845	1.22	885	1.40
	60	2882	530	0.60	530	0.60	530	0.60	670	0.74	730	0.89
	75	2306	430	0.42	430	0.42	430	0.42	565	0.54	640	0.66
250	45	4270	900	1.30	900	1.30	900	1.30	935	1.49	980	1.69
	60	3202	660	0.73	660	0.73	660	0.73	730	0.88	790	1.04
	75	2562	570	0.56	570	0.56	570	0.56	610	0.69	685	0.83
300	45	5123	990	2.04	990	2.04	990	2.04	1020	2.29	1070	2.55
	60	3843	735	1.29	735	1.29	735	1.29	795	1.49	865	1.71
	75	3074	600	0.95	600	0.95	600	0.95	—			
350	45	5977	1040	2.95	1040	2.95	1040	2.95	1075	3.24	1130	3.54
	60	4483	800	1.80	800	1.80	800	1.80	850	2.04	930	2.28
	75	3586	630	1.33	630	1.33	630	1.33	720	1.45	—	
400	45	6185	1055	3.56	1055	3.56	1055	3.56	1090	3.86	1170	4.17
	60	4392	790	1.98	790	1.98	790	1.98	875	2.17	1020	2.42
	75	4100	675	1.76	675	1.76	675	1.76	750	1.99	—	

NOTE: Unit sizes 30–125 do not have standard motors and drives. Standard motors and drives for unit sizes 150–125 are shaded.

⚠ DANGER ⚠

FIRE OR EXPLOSION HAZARD

- Failure to follow safety warnings exactly could result in serious injury, death, or property damage.
- Improper installation, adjustment, alteration, service, or maintenance can cause serious injury, death, or property damage.
- Installation and service must be performed by a qualified installer, service agency, or the gas supplier.
- Do not store or use gasoline or other flammable vapors and liquids in the vicinity of this or any other appliance.

WHAT TO DO IF YOU SMELL GAS

- Do not try to light any appliance.
- Do not touch any electrical switch; do not use any phone in your building.
- Leave the building immediately.
- Immediately call your gas supplier from a phone remote from the building. Follow the gas supplier's instructions.
- If you cannot reach your gas supplier, call the fire department.

For more information on Reznor HVAC products:

- **Contact your local Reznor representative at 1-800-695-1901**
- **Refer to the manuals and additional consumer materials found at www.reznorhvac.com**

